

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 4140-0610:124

Page 1 of 1

CATEGORY: Panic Hardware

LISTEE: Dorma Door Controls, Drawer AC, Reamstown PA 17567-0411
Contact: Rick Loose (717) 336-3881 Fax (717) 336-2106

DESIGN: Models F8300, Rim exit device and F8400, Surface vertical rod exit device. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation and UL label.

APPROVAL: Listed as panic hardware for use on doors having a fire-rating up to 3-hours. Model F8300 is intended for use on single swing or double outwardly swinging door assemblies. Model F8400 is intended for use on the inactive door of a pair of doors or on each leaf of a pair of doors that have the same direction and double egress. Door size maximum for both models is 4 ft. wide by 8 ft. high single doors and 8 ft. wide by 8 ft. high for double doors.

NOTE: Formerly 4140-1085:105

11-27-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 15, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager